

Diagram illustrating the electrical system for the 2nd floor (RZUT 2 PIĘTRA - OIOM). The system includes a power distribution unit (Q1) with a 63A circuit breaker, a 24VDC control system, and a fire alarm system (F1-F12). The system is connected to a main supply (X2) and a communication system (N2 EDS151). A table at the bottom lists 12 sets of outlets (Zestaw gniazd) with their respective specifications and locations.

Nr	1	2	3	4	5	6	7	8	9	10	11	12
Nazwa	Zestaw gniazd wtykowych IT pom. 3/36	Zestaw gniazd wtykowych IT pom. 3/36	Zestaw gniazd wtykowych IT pom. 3/36	Zestaw gniazd wtykowych IT pom. 3/36	Zestaw gniazd wtykowych IT pom. 3/36	Zestaw gniazd wtykowych IT pom. 3/36	Zestaw gniazd wtykowych IT pom. 3/36	Zestaw gniazd wtykowych IT pom. 3/41	Zestaw gniazd wtykowych IT pom. 3/41	Zestaw gniazd wtykowych IT pom. 3/41	REZERWA	REZERWA

Legend:

- obwody elektryczne
- - - obwody komunikacyjne
- ... obwody PE, PA(EC) oraz obwody kontroli parametrów układu

— obwody elektryczne  
 — obwody komunikacyjne  
 — obwody PE, PA(EC) oraz obwody kontroli parametrów układu

Rysunek	RZUT 2 PIĘTRA – OIOM SCHEMAT ROZDZIELNICY RIT23		Nr rys. E11
Inwestycja	MODERNIZACJA I ROZBUDOWA SZPITALNEGO ODDZIAŁU RATUNKOWEGO CELEM ROZWOJU SYSTEMU RATOWNICTWA MEDYCZNEGO W POWIECIE STASZOWSKIM		Data: 04.2019
Adres budynku	Staszów ul. 11 Listopada 78 dz. nr 5871/4		Skala
Branża	Elektryczna	Nr upr.	Podpis
Projektant	mgr inż. Krzysztof Lis	SWK/PW0E/0097/12	
Sprawdzający			